

## Amy Ow

---

**From:** Camille Leung  
**Sent:** Monday, September 23, 2019 3:15 PM  
**To:** Jonathan Tang  
**Cc:** 'noel@nexgenbuilders.com'; 'jtuttlec@aol.com'; 'Ralph Osterling'; Roland Haga; Amy Ow; Steve Monowitz  
**Subject:** RE: Highland Estates Lot 11 - Tree Crown Notes  
**Attachments:** Lot 11 C11.30.pdf

Hi Jonathan,

Looks good; please see comments below:

1. Please indicate that the trees in the riparian area will be protected by the chain link fence at the riparian area boundary, so they do not need to be individually protected. So Detail 6 on C11.60 should not be referenced for these trees in the riparian area.
2. Please adjust the Riparian Area Line to be located at the edge of the canopy/dripline of all riparian trees. Currently, the line is within the dripline of the 14" Oak tree. Also, please adjust the location of the chainlink fence for the 12" oak tree on east side to be outside of the dripline for that tree.
3. Please address how easements over the driveways have changed due to the relocation of the house further to the north by 5 feet. Please advise as to how recorded easements need to change.

Thanks

**From:** Jonathan Tang [mailto:jtang@BKF.com]  
**Sent:** Monday, September 23, 2019 9:05 AM  
**To:** Camille Leung <cleung@smcgov.org>  
**Cc:** 'noel@nexgenbuilders.com' <noel@nexgenbuilders.com>; 'jtuttlec@aol.com' <jtuttlec@aol.com>; 'Ralph Osterling' <ralph@ralphosterling.com>; Roland Haga <RHAGA@BKF.com>  
**Subject:** Highland Estates Lot 11 - Tree Crown Notes

**CAUTION:** This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

---

Camille,

Attached is the updated Highland Estates Lot 11 sheet C11.30 incorporating tree crown notes from Ralph Osterling. Please let us know today if you need hard copies (and number of copies of revised sheet) delivered to the County.

Thanks,

Jonathan

### JONATHAN TANG, PE

Project Manager

**BKF ENGINEERS** Delivering Inspired Infrastructure  
255 Shoreline Drive, Suite 200, Redwood City, CA 94065  
d 650.482.6306 [jtang@bkf.com](mailto:jtang@bkf.com) [BKF.com](http://BKF.com)



---

Confidentiality Notice: This email (including any attachment) is intended only for the individual or entity to which it is addressed and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If you are not the intended recipient, you are not authorized to intercept, read, print, retain, copy, forward, or disseminate this communication. If you have received this communication in error, please reply to the sender or call 650-482-6300, and then please delete this message from your inbox as well as any copies. Thank you, BKF Engineers 2019