

Amy Ow

From: Jessica Henderson-McBean <JHenderson-McBean@swca.com>
Sent: Wednesday, October 21, 2020 5:03 PM
To: robertpellegrine@yahoo.com
Cc: Bob Pellegrine; Noel Chamberlain; Kristen Outten; Amy Ow; Camille Leung
Subject: Highland Estates Site Visit - 10/21/2020

CAUTION: This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

Hi Bob,

Sorry I missed you onsite today, but I did chat with Ernesto and told him how great Lot 11 looks!

There is one outstanding item on Lots 9/10 which I discussed with Ernesto.

Lots 9/10

- Please install the drain inlet protection that Neil had previously discussed with you. Now that we are in the wet season, drain inlet protection is required by the SWPPP.

I didn't have any corrections for Lot 11.

Please feel free to give me a call if you would like to discuss!

Thanks!

Jessie Henderson-McBean
Project Manager / Biologist

SWCA Environmental Consultants
60 Stone Pine Road, Suite 100
Half Moon Bay, CA 94019
P 650.440.4160 x 6410 | C 805.712.8794



Visit Our New [Website!](#)

The contents of this email and any associated emails, information, and attachments are CONFIDENTIAL. Use or disclosure without sender's authorization is prohibited. If you are not an authorized recipient, please notify the sender and then immediately delete the email and any attachments.