

**COUNTY OF SAN MATEO
PLANNING AND BUILDING DEPARTMENT
CORRECTION LIST**

Date: November 25, 2020

Subject: Deferred submittal - Truss - Original review done in house

Address: 88 Cowpens Way Lot 11

PC#: BLD2016-00159

Plan checker: Bounmy Soumountha, S.E.

Phone: 650-522-2552

DIRECTIONS FOR RESUBMITTAL

IMPORTANT NOTICE: Please return both this correction list and any marked drawings or calculations along with your revised drawings when resubmitting. Please reference on the correction list where on the plans the corrections have been made to assist in providing a more timely review. Be advised that the plan review application for this project may expire 180 days from the date of original application.

PLAN CHECK COMMENTS

1. Please submit a letter of review by the CE/SE of record for the building confirming that the truss layout and individual truss calculations have been reviewed and found to be in compliance with the building design: Alternatively, the CE-SE of record may stamp and sign truss drawings and calculations with the CE-SE Engineer's shop drawing stamps and signatures.

Response: _____

(End of Comments)